

ID	OD	PEDESTAL	SLAB	TONS
48"	58"	6.0"	6"	0.69
60"	72"	8.0"	8"	1.41
72"	86"	8.0"	8"	2.02
84"	98"	7.0"	8"	2.62
96"	114"	7.5"	8"	3.54

MATERIALS:
CONCRETE: 4,000 PSI, TYPE I/II CEMENT
REINFORCEMENT PER ASTM C-478

NOTES:
FLEXIBLE CONNECTORS ARE AVAILABLE


PARTS SHOWN:
Ø 60" PEDESTAL TOP
Ø 60" ROUND TO SQUARE
Ø 60" 4'-0" BASE W/ Ø 34" HOLE

PRODUCTS FOLEY COMPANY		ROUND PRECAST PEDESTAL TOPS	1.7
-------------------------------------	--	--------------------------------	-----

NTS

NTS

gwinnettcounty



684 Winder Highway • Lawrenceville, GA 30045-5012
 678.376.6700 • www.gwinnetth2o.com

Fire Flow Test Report

Report Date: 1/26/2017

<p>Test Date: 1/25/2017</p> <p>Location: 3276 LAWRENCEVILLE SUWANEE RD</p> <p>Start Time: 2:25 pm</p> <p>Residual Hydrant ID: 2684153</p>	<p>Main Size: 16.00 in.</p> <p>End Time: 2:28 pm</p> <p>Static Pressure (psi): 110.00</p> <p>Total Test Flow Discharge: 1501.30</p>	<p>Test Type: Dual Hydrant</p> <p>Total Flow Time: 3.00 min</p> <p>Residual Pressure (psi): 90.00</p>
---	---	--

Flow @ 20 psi (gpm): 3382.22

Flow Hydrant Results

Flow Hydrant ID	Pitot Pressure	Nozzle Size (in.)	Coefficient	Conversion Factor	Test Flow (gpm)
2684154	80.00	2.50	0.90	29.84	1501.30

Providing Superior Water Service at an Excellent Value

Page 1 of 1

SHEET NUMBER

ISSUE FOR PERMITTING/BID